

Installation Guide

5050B-17'

Self Adhesive Silicone Seal

UL Tested and Certified for Fire and Smoke Doors



- * Seals against smoke, fire, air, sound and weather
- * Unaffected by sunlight, ozone and ultraviolet rays
- Excellent compression; door latches easily

Installation Instructions

- 1. The surface temperature of the frame must be above 50° F. for the adhesive
- 2. Clean frame with clean wipe provided to remove dust, oil, grease and dirt. Wax coated or high gloss painted surfaces may require roughening of the surface with a scotch brite pad or sandpaper so adhesive will properly bond.
- 3. Measure and pre-cut pieces to fit the head and jambs.
- 4. Remove protective backing I to 2 feet at a time.
- 5. Position on frame where illustrated, allowing approximately 1/16" between seal and frame for clearance when compressed.
- 6. Adhere by pressing firmly (approx. 15 lbs. pressure required) straight down along entire length of gasketing. Do not remove and relocate.
 - WARNING: Do not rub along length from one end toward other end during installation as gasket will stretch and not adhere properly.
- 7. Make sure the seal does not impede proper closing and latching of the door.













NGP-EDGE Sealing System (Category G) for use on category B wood type fire doors rated up to 20 minutes, single swing up to 4'0" x 8'0" and pairs up to 8'0" x 8'0"




POSITIVE PRESSURE TESTED GASKETING MATERIALS FOR FIRE DOORS. FOR APPLICATION TO HOLLOW-MET-AL-TYPE FIRE DOORS, RATED UP TO 3 HOURS AND WOOD-TYPE FIRE DOORS, RATED UP TO 1-1/2 HOURS. CATEGORY H

FOR APPLICATION TO CATEGORY B WOOD-TYPE FIRE DOORS RATED UP TO 20 MIN. CATEGORY G, H

Smoke & draft control gasketing (Category H) tested to UL 1784; meets requirements of NFPA 105, IBC for use on "S" label doors.

Made in USA



STORAGE AND SHELF LIFE

The adhesive on this seal has a shelf life of one year stored at 75°F and 50% relative humidity or less

SKU: N5050







